

# Zertifikat

mit überwachter Konformität

# Certificate

of surveyed conformity



Zertifikat Nr. *Certificate No.*  
J 50497194

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
Q.X.Y.

Unser Zeichen *Our Reference*  
01-SDW-50208429 005

Ausstellungsdatum  
11.03.2021

*Date of Issue*  
(day/mo/yr)

**Genehmigungsinhaber *License Holder***

NewSun PV Technology Co., Ltd.  
2F-Bldg. b JiaWen Park  
HengZeng Street  
Xin'an Community, Chang'an Town  
DongGuan City  
523883 Guangdong  
P.R. China

**Fertigungsstätte *Manufacturing Plant***

040-0002071162

**Prüfzeichen *Test Mark***



**Geprüft nach *Tested acc. to***

EN 60269-6:2011  
EN 60269-1:2007+A1+A2

**Zertifiziertes Produkt (Geräteidentifikation)**

*Certified Product (Product Identification)*

**Lizenzentgelte - Einheit**

*License Fee - Unit*

(Low-voltage Fuse for PV System)

Fuse-link

Type Designation : NSPV-32L.1 5

Rated Voltage : DC 1500V

Rated Current : 8A; 10A; 12A; 15A; 16A; 20A; 25A; 30A; 32A;  
35A; 40A; 45A and 50A

Rated Breaking Capacity: 20kA

Breaking Range : gPV

Rated Power Dissipation: no more than 6,1W at 0,7In  
no more than 13,6W at In

Size : 14mm\*85mm

Arc Voltage Limits : 5000V (peak value)

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.  
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.  
This certificate is based on our Testing and Certification Regulation. The product  
fulfills above mentioned requirements, the production is subject to surveillance.

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Kenny Shi

NewSun PV Technology Co., Ltd.  
Mr. Jason Jian

Date : 11.03.2021  
Our ref. : SDW 01  
Your ref.: Q.X.Y.

2F-Bldg. b JiaWen Park  
HengZeng Street  
Xin'an Community, Chang'an Town  
DongGuan City  
523883 Guangdong  
P.R. China

**Ref : J Certificate of Surveyed Conformity**

Type of Equipment : Low-voltage Fuse for PV System  
Model Designation : See Certificate  
Certificate No. : J 50497194 0001  
Report No. : 50208429 005

Dear Mr. Jason Jian,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

  
Kenny Shi

cc: ZHEJIANG CHIFENG ELECTRIC

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询