


Norm: IEC 61869-1, 61869-6, 61869-10  
 Insulation level: 0,72kV/3kV/-  
 Temperature category: -10/60°C  
 Accuracy class:  
 CI 0.5  
 Ratio: 50//225mV ext.500%  
 KPCR: 5

Dept. GWP	Technical reference	Created by P. Bacher 04.05.2020	Approved by N. Juschicz 04.05.2020
 A3/1:1	Document type Drawing	Document status Released	
	Title Current Sensor LV 50-250A	DWG No. L005R-21	
		Rev. 1	Date of issue 04.05.2020